

NOTES:

1. UNIT MUST HAVE CLEARANCES AS FOLLOWS:
TOP– DO NOT RESTRICT.
SIDES AND END– 6’ FROM SOLID SURFACE.
FOR AIRFLOW SIDE– 8’ REQUIRED FOR COIL SERVICE AREA.
IF MULTIPLE UNITS ARE INSTALLED AT THE SAME SITE, A MINIMUM SEPERATION OF 10FT (3M)
BETWEEN THE SIDES OF THE MACHINES IS REQUIRED TO MAINTAIN PROPER AIRFLOW.
2. FACTORY WIRING IS IN ACCORDANCE WITH UL 1995 STANDARDS. FIELD MODIFICATIONS OR
ADDITIONS MUST BE IN COMPLIANCE WITH ALL APPLICABLE CODES.
3. WIRING FOR MAIN FIELD SUPPLY MUST BE RATED 75C MINIMUM. USE COPPER FOR ALL UNITS.
4. TEMPERATURE RELIEF DEVICES ARE LOCATED ON LIQUID LINES, AND ECONOMIZER ASSEMBLIES
AND HAVE 3/8" SAE FLARE CONNECTION. DO NOT CAP OR OTHERWISE OBSTRUCT
TEMPERATURE/PRESSURE RELIEF.
5. PRESSURE RELIEF DEVICES ARE LOCATED ON THE EVAPORATOR (3/4" NPT MALE CONNECTOR) AND ON
EACH OIL SEPERATOR (3/8" FLARE CONNECTOR).
6. DIMENSIONS SHOWN ARE IN INCHES, DIMENSIONS IN [] ARE IN MM.



JOB NAME:	—
BUYER:	
SALES ENG.:	
MODEL NO.:	—
JOB NO.:	—
P.O. NO.:	
PREPARED BY:	—
ELECTRICAL CHARACTERISTICS:	—
JOB SITE LOCATION:	
SALES OFFICE:	
REFRIGERANT NO.:	—
NOTES:	
COND: 1, 1A–1F COOLER: 2, 2A–2G MACHINE ASSEMBLY NOTES	
DATE: —	
REVISION: —	
THIS DOCUMENT IS THE PROPERTY OF CARRIER CORP. AND IS DELIVERED UPON THE EXPRESS CONDITION THAT THE CONTENTS WILL NOT BE DISCLOSED OR USED WITHOUT CARRIER CORP. WRITTEN CONSENT. SUBMISSION OF THESE DWG'S. OR DOCUMENTS DOES NOT CONSTITUTE PART PERFORMANCE OR ACCEPTANCE OF CONTRACT.	
CARRIER DWG # 01X60001000-1A4 REV. — SHT 01 OF 01 DATE: 7-15-2020 SUPERSEDES DWG. DA LD: —	
30XV	
SHT 07 OF 07	